

Central Kitsap Fire and Rescue
Station 57

Bid No. 2022-STA57BUILD-50-01

ADDENDUM # 3
October 19, 2022

TO ALL BIDDERS:

The Bid Documents issued 09/20/2022 for the project noted above are amended by this Addendum # 3

Receipt of this addendum shall be acknowledged by inserting its number in the space provided on the bid form.

GENERAL COMMENTS

- ITEM 1. There have been some questions regarding the fencing around the property and who is providing them and where the details are for each fence type.
- a. The "BY OTHERS" note as seen on the civil/landscape sheets is referencing that civil/landscaping is not detailing those specific fences. The GC is still responsible for providing these fences.
 - b. The chain link around the property is detailed on the civil sheet C5.32. Civil is providing the chain link details. The fence is by the GC.
 - c. The cedar fence detail on C5.32 is for the northern property line fence shown on C2.00. The fence is by the GC
 - d. The cedar fencing detail on L2.00 is for the patio fence. The fence is by the GC.
 - e. Sheet A12.01 has the details for the sliding gate. The gate is by the GC.
 - f. The info needed for the wood fencing is on their respective details including the wood species, grade, size, fasteners...
- ITEM 2. Can the CAT6A cabling and Patch Panels be from a manufacturer listed in 2.04B like Berk-Tek Leviton? Why specify only the CAT6A cabling and Patch Panels to be manufactured by Commscope and not the CAT6 cabling as well?
- a. The owner's preferred manufacturer for comm/patch panels is Commscope. Please bid accordingly.

SUBSTITUTION REQUESTS

- ITEM 1. 23 37 00 LOUVERS.
- a. American Warming. APPROVED for manufacture only. Exact louver designs to be reviewed during submittals.

END OF ADDENDUM # 3